

---

# ENERGY AUDIT REPORT

GOKHALE INSTITUTE OF POLITICS AND ECONOMICS  
PUNE


---



**AUGUST 18**

---

IGNISENSE ECOENERGY LLP



---

### Acknowledgement

We would like to express our sincere thanks to Pune International Centre, Prof. Amitava Mallik (Padma Shree), for the opportunity to perform Energy Audit of Gokhale Institute of Politics and Economics, (GIPE), Pune.

We also acknowledge with thanks the co-operation and the support extended by the GIPE team during the conduct of this audit.

We sincerely acknowledge the contribution of the following dignitaries, Admin and maintenance personnel because of whom the study could progress smoothly.

Col. Kapil Jodh  
Mr. Deepak Ganbavale  
Mr. Mahesh Deodhar  
Mr. Santosh Jadhav

We are also thankful to the staff of GIPE, PIC and Ignisense team without whom the audit was not possible.



### Audit Team Member

The team deputed for the GIPE is well experienced and qualified personnel as follows.

Sr. No.	Name	Qualification, experience and Expertise
1	Mr. Aroha Kulkarni	Certified Energy Auditor – EA 13147, 16+ years of experience, Solar PV audit, Regulatory and policy, merger and acquisition of RE project & Energy Audit
2	Dr. Asmita Marathe	Certified Energy Auditor – EA 4621, 16+years of experience in Solar, Boilers, heat exchangers, power plant and manufacturing plant, Energy Audit, Training
3	Mr. Prasad Badakh	Electrical Expert, 14+ years of experience in Solar PV plant O&M, Solar PV plant audit and performance assessment.
4	Mrs. Shruti Kulkarni	MBA (Business Analytics), BE (E & TC)
5	Ms. Poonam Chaudhari	BE (Electrical Engineering)

The team deputed by PIC is as follows,

Sr. No.	Name	Organization
1	Mr. Mahesh Deodhar	PIC
2	Mr. Siddhartha Bhagwat	PIC
3	Ms. Shalwi Pawar	PIC
4	Mr. Vedant Page	GIPE
5	Ms. Mihika Asawa	GIPE




## Executive Summary & Critical Comments

### Executive Summary:

Location		Units
<b>Main Campus</b>	Total Energy Consumption from MSEDCL	48454 kWh
	Annual Solar Energy Generation	95487 kWh
<b>Residential Campus</b>	Total Energy Consumption from MSEDCL	147002 kWh


### Monthly Consumption pattern

Month	Consumption
Apr-23	15362
Mar-23	11094
Feb-23	12749
Jan-23	11935
Dec-22	12638
Nov-22	10689
Oct-22	13742
Sep-22	11831
Aug-22	10659
Jul-22	12029
Jun-22	12335
May-22	11939



Above table and graph shows the monthly unit consumption for Residential Area of 'Gokhale Institute, Pune' from May-2022 to April-2023 having average monthly consumption of 12,250 units.


Month	Consumption
Apr-23	1756
Mar-23	1409
Feb-23	1225
Jan-23	1107
Dec-22	1120
Nov-22	1050
Oct-22	1117
Sep-22	1488
Aug-22	1041
Jul-22	955
Jun-22	1262
May-22	1190



Above table and graph shows the monthly unit consumption for Campus Area of Gokhale Institute, Pune from May-2022 to April-2023 having average monthly consumption of 1,225 units.

#### Monthly generation pattern

Month	Consumption
Apr-23	9941
Mar-23	8372
Feb-23	9050
Jan-23	7800
Dec-22	6759
Nov-22	7336
Oct-22	7683
Sep-22	7264
Aug-22	6883
Jul-22	6211
Jun-22	7973
May-22	10215



Above table with graph shows that, monthly solar generation for Residential Area of 'Gokhale Institute, Pune' from May-2022 to April-2023 duration.





---

**Critical Comments:**

1. The solar PV plant is under performing.
2. Installed capacity of the solar power plant is higher than the total consumption of Campus leading to banking of solar generation with MSEDCL. The lapsation of units at the end of financial year is causing financial loss as the reimbursement received from MSEDCL for lapse units is at much lower tariff than Solar PPA rate.
3. There are hot spots and the burning of panel back sheet observed.
4. Inverter DCDB bypassed and one inverter display cover broken hampering its IP rating
5. Lift at the new building is recently installed, hence the load is not counted.
6. Pump data is unavailable and pumps are running on SIS meter.
7. All the utilities and electrical appliances are counted either visiting the premises and or interviewing the occupants.
8. Harmonics and Power factor fluctuation are seen in the power analyzer readings.
9. DG set is sparingly used, however the data for the usage is not traceable.
10. Potential electrical safety and fire hazards have been highlighted.
11. Good potential to effectively use day lightning so as to reduced lighting load.
12. Water consumption data available only for residential campus.
13. B Phase wire does not have proper insulation in boys hostel it may lead to fire hazards.



---

## INTRODUCTION OF GIPE

Sector: Educational Institute.  
Name: Gokhale Institute of Politics and Economics.  
Year of Establishment:  
Address:  
Contact details:

Gokhale Institute of Politics and Economics (GIPE), commonly known as Gokhale Institute, is one of the oldest research and training institutes for economics in India. The institute was founded on 6 June 1930 by R. R. Kale as a centre for research and higher learning in economics. The institute was set up with an objective of conducting research on the economic and political problems of India and to train researchers in these disciplines.

### Purpose of the Energy Audit

The primary objective of energy audit is to determine the ways to reduce the energy consumption so as to lower the operating cost and understanding the energy consumption trends as a prerequisite microgrid. We are sure energy audit will provide a "bench mark" for managing energy in the organization and also may provide the basis for effectively planning energy utilization throughout the organization. The Energy Audit has been carried out from 06 June 2023 to 30 June 2023.

## APPROACH SCOPE AND METHODOLOGY

### SCOPE OF WORK –

- 1.1 Collect historical energy data and analysis the same to identify Key Result Area (KRA).
- 1.2 Interact with relevant officials to understand present approach and practice followed to monitor energy use.
- 1.3 Collect relevant equipment energy data to understand equipment selection level energy performance.
- 1.4 Schedule and conduct physical measurement wherever necessary to confirm actual energy use.
- 1.5 Measure and then evaluate energy performance and compare with manufacturer's data. This helps to establish actual plant demand vis-a-vis it's capacity. This includes measured kW, kVa, P.F. of operating motor, Air flow and its air handling capacity, etc.
- 1.6 Analysis will evolve measures to reduce operating energy cost.
- 1.7 Estimate broad base realistic cost benefit analysis for recommendations.
- 1.8 Identify sources with possible vendor details to simplify implementation.
- 1.9 Suggest energy consumption reporting system to create energy consumption records and ensure implementation, so as to provide sustained results. This will help management to establish control over energy cost.
- 1.10 Electrical Distribution System & Transformer
- 1.11 Illumination System
- 1.12 DG Set, Water Pump
- 1.13 Solar Photovoltaic system – performance assessment – Thermography, IV curve analysis on sample basis and actual vs. design performance checking.
- 1.14 Detailed Power Quality Analysis (As per scope mentioned in RFQ)



---

## APPROACH AND METHODOLOGY

- 1 Ignisense has appointed Energy auditors, two Senior Energy Engineers and a Thermography expert having adequate experience of similar assignments.
- 2 Ignisense has initiated communication with the CLIENT and discussed preliminary Checklist for the detailed information required during the first visit.
- 3 Ignisense with the GIPE team and PIC members has collected the data in different areas/disciplines like Electrical, Illumination and Mechanical Utilities like Air Conditioning System, Illumination, and Pumping system.
- 4 Detailed checklist is prepared for each of the Energy / Utility Systems involved in the study.
- 5 'On-going' Energy Conservation Projects already initiated by the Client, has been reviewed and specifically documented.
- 6 Requisite copies of the final report are prepared and submitted to the CLIENT for record and subsequent implementation.





### SUMMARY OF GIPE

GIPE has two premises, educational institute and residential area. The meter details are as per the Annexure A


Sr. No	Premises	Total consumption in last 12 months					
		Electricity Units (kWh)	Amount in Rs.	Water Consumption	Amount in Rs.	Diesel Ltrs	Amount in Rs.
1	GIPE university premises	48,454	5,19,487	Data not available			
2	GIPE Residential Premises	1,47,002	16,45,083	Data not available			
3	SIS premises – GIPE payment	NA		Data not available			

### Energy Consumption of the institute

TOD Zone wise energy consumption of institute for last 12 months is as follows

Month	Units			
	A zone	B zone	C zone	D zone
Apr-23	1505	1727	31	1757
Mar-23	1463	1594	201	1409
Feb-23	1179	724	20	1225
Jan-23	1101	776	7	1107
Dec-22	1171	1050	79	1120
Nov-22	1104	1045	2	1015
Oct-22	1277	1595	300	1117
Sep-22	1407	2168	524	1264
Aug-22	1389	1058	195	1043
Jul-22	1263	1555	404	960
Jun-22	1579	1505	269	1262
May-22	1553	1085	79	1191





Above table with graph shows that, zone wise consumption for Campus Area of Gokhale Institute, Pune from May-2022 to April-2023 duration.

**Single Line Diagram:**

**Electrical SLD**

GIPE University: Not Available.

GIPE residential: Not Available.

**Hot Water System**

GIPE University: Not Available.

GIPE residential: Two systems Available in dismantled condition.



## Energy Conservation Projects

Energy Conservation Measure Number: 1				
1	Title of Recommendation	To replace old tube lights with the efficient luminaries under <b>public service tariff</b> .		
2	Description of Existing System and its operation	Presently there are T12, T8 and T5 old tube lights.		
3	Description of Proposed System	To install LED tube lights.		
4	Existing System	Presently there are old tube lights which are power consuming.		
5	Modified System	LED tube lights are energy efficient.		
		T5	T8	T12
6	Energy Cost Savings (Rs/day):	Rs. 54.44	Rs. 247.39	Rs. 35.56
	Savings in one year, (lakhs):	Rs.19870.16	Rs. 90297.04	Rs. 12979.70
	Savings in Next 5 Years (Lakh.):	Rs. 99350.8	Rs. 451485.2	Rs. 64898.5
7	Investment (Lakh.) (This cost is very approximate including pipeline modification)	Rs. 5850	Rs. 47775	Rs. 20150
8	Simple Payback Period (Months)	12.17	6.35	5.41
9	Issues in implementation			

Public Service (>50KWh)	ED=16%			
Tube Cost	325			
<b>Present Case</b>				
		T8	T12	T5
Tubelight	Nos	147	18	62
Wattage	Watt	41	45	30
Hours of operation/day	Hrs	8	8	8
Days of operation in a year	Nos	260	260	260
Total energy consumption in year	kWh	12536.16	1684.8	3868.8
Variable Tariff	Rs/kWh	12.84	12.84	12.84
Annual Running cost	Rs	160964.2944	21632.83	49675.39



Energy Efficient Scenario				
Tubes which have to be replace		T8	T12	T5
LED Wattage	Watt	18	18	18
Hours of operation/day	Hrs	8	8	8
Days of operation in a year	Nos	260	260	260
Total energy consumption in year	kWh	5503.68	673.92	2321.28
Variable Tariff	Rs/kWh	12.84	12.84	12.84
Annual Running cost	Rs.	70667.2512	8653.133	29805.24
Annual saving	Rs.	90297.0432	12979.7	19870.16
Capital investment	Rs.	47775	5850	20150
Payback Period	Years	0.53	0.45	1.01
Payback Period	Months	6.35	5.41	12.17

Energy Conservation Measure Number: 1				
1	Title of Recommendation	To replace old tube lights with the efficient luminaries under <b>commercial tariff</b> .		
2	Description of Existing System and its operation	Presently there are T12, T8 and T5 old tube lights.		
3	Description of Proposed System	To install LED tube lights		
4	Existing System	Presently there are old tubes which are power consuming.		
5	Modified System	LED tube lights are more efficient.		
6	Energy Cost Savings (Rs/day):	T5 Rs. 49.22	T8 Rs. 85.22	T12 Rs. 5.36
	Savings in one year, (lakhs):	Rs.17966.71	Rs.31103.65	Rs.1956.05
	Savings in Next 5 Years (Lakh.):	Rs. 89833.5	Rs.155518.25	Rs. 9780.25
7	Investment (Lakh.) (This cost is very approximate including pipeline modification)	Rs. 20150	Rs. 18200	Rs. 975
8	Simple Payback Period (Months)	13.44	7.08	6.00
9	Issues in implementation			





Commercial (0-20KWh)	ED=21%			
Tube Cost	325			
<b>Present Case</b>				
		T8	T12	T5
Tubelight	Nos	56	3	62
Wattage	Watt	41	45	30
Hours of operation/day	Hrs	8	8	8
Days of operation in a year	Nos	260	260	2360
Total energy consumption in year	kWh	4775.68	280.8	3868.8
Variable Tariff	Rs/kWh	11.61	11.61	11.61
Annual Running cost	Rs	55445.64	3260.088	44916.77

<b>Energy Efficient Scenario</b>				
Tubes which have to be replace		T8	T12	T5
LED Wattage	Watt	18	18	18
Hours of operation/day	Hrs	8	8	8
Days of operation in a year	Nos	260	260	260
Total energy consumption in year	kWh	2096.64	112.32	2321.28
Variable Tariff	Rs/kWh	11.61	11.61	11.61
Annual Running cost	Rs.	24341.99	1304.035	26950.06
Annual saving	Rs.	31103.65	1956.053	17966.71
Capital investment	Rs.	18200	975	20150
Payback Period	Years	0.59	0.50	1.12
Payback Period	Months	7.08	6.00	13.44

<b>Energy Conservation Measure Number: 1</b>				
1	Title of Recommendation	To replace old tube lights with the efficient luminaries under <b>Residential tariff</b> .		
2	Description of Existing System and its operation	Presently there are T5, T8 and T12 old tube lights.		
3	Description of Proposed System	To install LED tube lights		
4	Existing System	Presently there are old tubes which are power consuming.		
5	Modified System	LED tubes are more energy efficient.		
6		T5	T8	T12
	Energy Cost Savings (Rs/day):	Rs.13.93	Rs.85.09	Rs.21.55
	Savings in one year, (lakhs):	Rs.5083.85	Rs.31059.16	Rs.7864.08
	Savings in Next 5 Years (Lakh.):	Rs.25419.25	Rs.155295.8	Rs.39320.4
7	Investment (Lakh.) (This cost is very approximate including pipeline modification)	Rs.5200	Rs.16575	Rs.3575
8	Simple Payback Period (Months)	12.24	6.36	5.40
9	Issues in implementation			





Residential (100-300)	ED=16%			
Tube Cost	325			
<b>Present Case</b>				
		T8	T12	T5
Tubelight	Nos	51	11	16
Wattage	Watt	41	45	30
Hours of operation/day	Hrs	8	8	8
Days of operation in a year	Nos	260	260	260
Total energy consumption in year	kWh	4349.28	1029.6	998.4
Variable Tariff	Rs/kWh	12.73	12.73	12.73
Annual Running cost	Rs	55366.33	13106.81	12709.63

<b>Energy Efficient Scenario</b>				
Tubes which have to be replace		T8	T12	T5
LED Wattage	Watt	18	18	18
Hours of operation/day	Hrs	8	8	8
Days of operation in a year	Nos	260	260	260
Total energy consumption in year	kWh	1909.44	411.84	599.04
Variable Tariff	Rs/kWh	12.73	12.73	12.73
Annual Running cost	Rs.	24307.17	5242.723	7625.779
Annual saving	Rs.	31059.16	7864.085	5083.853
Capital investment	Rs.	16575	3575	5200
Payback Period	Years	0.53	0.45	1.02
Payback Period	Months	6.36	5.40	12.24



Energy Conservation Measure Number: 2		
1	Title of Recommendation	To replace fans with the efficient BLDC fans under <b>Residential tariff</b> .
2	Description of Existing System and its operation	Presently there are old fans
3	Description of Proposed System	To install fans
4	Existing System	Presently there are old normal fans which consumes more power.
5	Modified System	BLDC fans are much more efficient than normal fans as they consume less power.
6	Energy Cost Savings (Rs/day):	Rs. 522.31
	Savings in one year, (lakhs)	Rs. 190644.5
	Savings in Next 5 Years (Lakh.)	Rs. 953222.5
7	Investment (Lakh.) (This cost is very approximate including pipeline modification)	Rs. 504000
8	Simple Payback Period (Months)	31.72
9	Issues in implementation	

Residential (100-300 unit)		
Fan Cost-2800		
Present Case		
Fan	Nos	180
Wattage	Watt	70
Hours of operation/day	Hrs	8
Days of operation in a year	Nos	260
Total energy consumption in year	kWh	26208
Variable Tariff	Rs/kWh	12.73
Annual Running cost	Rs	333627.8

Energy Efficient Scenario		
Fan		180
Wattage	Watt	30
Hours of operation/day	Hrs	8
Days of operation in a year	Nos	260
Total energy consumption in year	kWh	11232
Variable Tariff	Rs/kWh	12.73
Annual Running cost	Rs.	142983.4

Annual saving	Rs.	190644.5
Capital investment	Rs.	504000
Payback Period	Years	2.64
Payback Period	Months	31.72397



Energy Conservation Measure Number: 2		
1	Title of Recommendation	To replace fans with the efficient BLDC fans under <b>commercial tariff</b> .
2	Description of Existing System and its operation	Presently there are old fans
3	Description of Proposed System	To install fans
4	Existing System	Presently there are old normal fans which consumes more power.
5	Modified System	BLDC fans are much more efficient than normal fans as they consume less power.
6	Energy Cost Savings (Rs/day):	Rs. 727.77
	Savings in one year, (lakhs)	Rs. 265636.8
	Savings in Next 5 Years (Lakh.)	Rs. 1328184
7	Investment (Lakh.) (This cost is very approximate including pipeline modification)	Rs. 770000
8	Simple Payback Period (Months)	34.78
9	Issues in implementation	

Commercial (0-20 unit)		
Fan Cost-2800		
Present Case		
Fan	Nos	275
Wattage	Watt	70
Hours of operation/day	Hrs	8
Days of operation in a year	Nos	260
Total energy consumption in year	kWh	40040
Variable Tariff	Rs/kWh	11.61
Annual Running cost	Rs	464864.4

Energy Efficient Scenario		
BLDC Fan		275
Wattage	Watt	30
Hours of operation/day	Hrs	8
Days of operation in a year	Nos	260
Total energy consumption in year	kWh	17160
Variable Tariff	Rs/kWh	11.61
Annual Running cost	Rs.	199227.6

Annual saving	Rs.	265636.8
Capital investment	Rs.	770000
Payback Period	Years	2.90
Payback Period	Months	34.78434



Energy Conservation Measure Number: 2		
1	Title of Recommendation	To replace fans with the efficient BLDC fans under <b>Public Service tariff.</b>
2	Description of Existing System and its operation	Presently there are old fans
3	Description of Proposed System	To install fans
4	Existing System	Presently there are old normal fans which consumes more power.
5	Modified System	BLDC fans are much more efficient than normal fans as they consume less power.
6	Energy Cost Savings (Rs/day):	Rs. 679.02
	Savings in one year, (lakhs)	Rs. 247842.8
	Savings in Next 5 Years (Lakh.)	Rs. 1239214
7	Investment (Lakh.) (This cost is very approximate including pipeline modification)	Rs. 649600
8	Simple Payback Period (Months)	31.45
9	Issues in implementation	

Public Service (>50 KWh)		
Fan Cost-2800		
Present Case		
Fan	Nos	232
Wattage	Watt	70
Hours of operation/day	Hrs	8
Days of operation in a year	Nos	260
Total energy consumption in year	kWh	33779.2
Variable Tariff	Rs/kWh	12.84
Annual Running cost	Rs	433724.9

Energy Efficient Scenario		
BLDC Fan		232
Wattage	Watt	30
Hours of operation/day	Hrs	8
Days of operation in a year	Nos	260
Total energy consumption in year	kWh	14476.8
Variable Tariff	Rs/kWh	12.84
Annual Running cost	Rs.	185882.1

Annual saving	Rs.	247842.8
Capital investment	Rs.	649600
Payback Period	Years	2.62
Payback Period	Months	31.45219





Energy Conservation Measure Number: 3		
1	Title of Recommendation	Installation of heat pump water heating system
2	Description of Existing System and its operation	Presently there are Geyser.
3	Description of Proposed System	To install heat pumps
4	Existing System	Presently there are geyser in residential area
5	Modified System	Heat pumps are more energy efficient
6	Energy Cost Savings (Rs/day):	Rs. 7116.593
	Savings in one year, (lakhs)	Rs. 2597557
	Savings in Next 5 Years (Lakh.)	Rs. 12987785
7	Investment (Lakh) (This cost is very approximate including pipeline modification)	Rs. 5000000
8	Simple Payback Period (Months)	23.09
9	Issues in implementation	

<b>Residential (100-300)</b>	ED=16%	
Heat pump cost	500000	
No of Heat pump	10	
<b>Present Case</b>		
Geyser	Nos	56
Wattage	Watt	3000
Hours of operation/day	Hrs	5
Days of operation in a year	Nos	275
Total energy consumption in year	kWh	231000
Variable Tariff	Rs/kWh	12.73
Annual Running cost	Rs	2940630

Energy Efficient Scenario		
Heat Pump		10
Wattage	Watt	19600
Hours of operation/day	Hrs	5
Days of operation in a year	Nos	275
Total energy consumption in year	kWh	26950
Variable Tariff	Rs/kWh	12.73
Annual Running cost	Rs.	343073.5

Annual saving	Rs.	2597557
Capital investment	Rs.	5000000
Payback Period	Years	1.92
Payback Period	Months	23.09863





Energy Conservation Measure Number:		
1	Title of Recommendation	Automation of lighting system in library area
2	Description of Existing System and its operation	Most of the lights are kept on continuously in book shelf area.
3	Description of Proposed System	Proximity sensor-based automation of lighting to be implemented in the entire book shelf area which will switch on the lights in particular area if there is occupancy in that area.
4	Existing System	Manual switching of lights
5	Modified System	Automatic on-off system
6	Energy Cost Savings (Rs/day): Savings in one year, (lakhs) Savings in Next 5 Years (Lakh.)	
7	Investment (Lakh.) (This cost is very approximate including pipeline modification)	
8	Simple Payback Period (Months)	
9	Issues in implementation	



Energy Conservation Measure Number: 7		
1	Title of Recommendation	Installation of biogas plant
2	Description of Existing System and its operation	Presently LPG cylinders are used in canteen for cooking and the wet waste is disposed in the waste disposal trucks of PMC
3	Description of Proposed System	Wet kitchen and garden waste to be fed to bio digester for converting it to biogas and manure
4	Existing System	LPG cylinders used for cooking
5	Modified System	To install biogas plant which will partly replace LPG cylinders.
6	Energy Cost Savings (Rs/day):	Rs. 246.57
	Savings in one year, (lakhs)	Rs. 90000
	Savings in Next 5 Years (Lakh.)	Rs. 450000
7	Investment (Lakh.) (This cost is very approximate including pipeline modification)	Rs. 110000
8	Simple Payback Period (Months)	66
9	Issues in implementation	

Present Case		
Cylinders	Nos	10
Cost	Rs	2000
Running Cost	Rs	20000

Energy Efficient Scenario		
Biogas Plants		1
Cost	Rs.	110000
Capital investment	Rs.	110000
Payback Period	Years	5.50
Payback Period	Months	66



### Solar PV plant performance assessment

#### Plant performance:

The Solar power plant is set-up under OPEX route by M/s Fourth Partner Energy Pvt. Ltd. and was installed and commissioned on [redacted] 2016. Capacity of a plant as per PPA is 100 kWp and is connected to GIPE's main LT panel at 440V along with the Net Metering arrangement with MSEDCL.

Following is annual generation as per MSEDCL generation meter readings for year 2022

Month	Solar Generation (kWh)
Jan	9,008
Feb	9,677
Mar	9,901
Apr	9,777
May	10,215
Jun	7,973
Jul	6,211
Aug	6,883
Sep	7,264
Oct	7,683
Nov	7,336
Dec	6,759
Total	98,687

Plant Capacity as per PPA	kWp	100
Annual specific generation for 2022	kWh/kWp/year	986.87
Estimated Sp generation for Pune	kWh/kWp/year	1387
System performance	%	71%

Actual performance of the system is almost 37% lower as compared to estimated generation. Even with this under performance of the system, the solar generation is in excess of the actual consumption of the campus indicating the system is oversized for the campus. M/s GIPE is suffering financial losses on account of adjusted units as the MSEDCL tariff for unadjusted units will be much lower than the PPA tariff. As of 31 March 2023, there were [redacted] units of solar electricity were banked with MSEDCL that have lapsed leading to loss of approx. \_\_\_\_\_ Rs.



---

**From above it is clear that plant is underperforming as the generation of about 70% of estimated generation based on solar irradiation for location in Pune**




### Thermography of Solar Plant



Picture markings:

Measurement Objects	Temp. [°C]	Emiss.	Refl. temp. [°C]	Remarks
Hot spot 1	60.6	0.90	20.0	-

Figure 1 Heating of junction box due to shadow on modules



Picture markings:

Measurement Objects	Temp. [°C]	Emiss.	Refl. temp. [°C]	Remarks
Hot spot 1	83.9	0.90	20.0	-

Figure 2 Hotspot due to soiling on module



Picture markings:

Measurement Objects	Temp. [°C]	Emiss.	Refl. temp. [°C]	Remarks
Hot spot 1	90.2	0.90	20.0	-

Figure 3 Hotspot due to soiling on module








Figure 4 No Excess Heating in Inverter





Figure 5 Partial over heating of module





Picture markings:

Measurement Objects	Temp. [°C]	Emiss.	Refl. temp. [°C]	Remarks
Hot spot 1	36.2	0.90	20.0	-

Figure 6 Overheating of Busbar






Picture markings:

Measurement Objects	Temp. [°C]	Emiss.	Refl. temp. [°C]	Remarks
Hot spot 1	36.4	0.90	20.0	-


Figure 7 Overheating of Busbar



Picture markings:

Measurement Objects	Temp. [°C]	Emiss.	Refl. temp. [°C]	Remarks
Hot spot 1	51.4	0.90	20.0	-



Figure 8 Overheating of Busbar



Picture markings:

Measurement Objects	Temp. [°C]	Emiss.	Refl. temp. [°C]	Remarks
Hot spot 1	42.7	0.90	20.0	-

Figure 9 overheating of MCCB Main Busbar



Picture markings:

Measurement Objects	Temp. [°C]	Emiss.	Refl. temp. [°C]	Remarks
Hot spot 1	42.5	0.90	20.0	-

Figure 10 Overheating of Busbar



Power consumption Patterns:

i. During Peak Solar Generation Hours




Figure 11: Total Active Power (KW) Consumption of Campus

At the time of taking these measurements weather was intermittently cloudy so the direction of power is alternating between import and export. Also, it is observed that the load curve is not stable and having frequent variations. Refer ANNEXURE - D for detailed data of One second interval.






Figure 12: Phase-Wise Active (KW) Power Consumption of Campus

During the time of taking these measurements weather was intermittently cloudy so the direction of power is alternating between import and export. From above graph, it can be seen that the load is not balanced between the three phases and is varying constantly. Refer ANNEXURE – D for detailed data of One second interval.








Figure 11: Apparent Power (KVA) Consumption

The direction of power is alternating between import and export. From above graph, it can be seen that the load is not balanced between the three phases and is varying constantly. Refer ANNEXURE – D for detailed data






Figure 14: Active Power (KW) and Apparent Power (kVA)

The huge difference is seen between active and apparent power is on account of improper Power Factor (PF). Refer ANNEXURE – D for detailed data.






Figure 15 Phase wise current

As seen in above graph, load imbalance is observed in R-Phase, Y-Phase and B-Phase and there is significant current variation in current measured in each phase. Refer ANNEXURE – D for detailed data






Figure 16: Current Harmonics (110v)

The voltage harmonics is within range as per IEEE standards but current harmonics is very high especially in R-Phase with average value of 79%. This is on account of harmonics induced by non-linear loads like VFDs, LEDs IT related loads and UPS. Refer ANNEXURE – D for detailed data








Figure 17: Power Factor

The current APFC is not able to maintain the Power Factor and the PF is not same in all three phases because of load imbalance. Refer ANNEXURE -D for detailed data



I. During Night Hours




Figure 18 Total Active Power (KW) Consumption during Night

Also, it is observed that the load curve is not stable and having frequent variations all through out the day. At night time i.e. 9.30 PM to 6.30 AM the load is almost constant.



Channel	Color	Current RMS	Current RMS	Current RMS	Wattage RMS	Wattage RMS	Wattage RMS
2300V	Red	2.0250A	2.2220A	2.2000A	-8.214W	8.831W	20.930W
2300V	Green	1.0760A	1.0640A	1.0640A	-18.44W	8.828W	8.3110W
2300V	Blue	0.0A	0.0A	0.0A	-0.070W	1.241W	21.180W




Figure 19 Phase-Wise Active (KW) Power Consumption during Night

From above graph, it can be seen that the load is not balanced between the three phases and is varying constantly. Night time load is almost constant in Y-phase and slightly varying in R-Phase on account of air conditioning load in B-Phase there is no load at night time. Refer ANNEXURE – D for detailed data of One second interval.










Figure 21 Active Power (KW) and Apparent Power (KVA)

The huge difference is seen between active and apparent power is on account of improper Power Factor (PF). Refer ANNEXURE – D for detailed data.






Figure 22 Phase wise current

As seen in above graph, load imbalance is observed in R-Phase, Y-Phase and B-Phase and there is significant current variation in current measured in each phase. Refer ANNEXURE – D for detailed data






Figure 21 Current Harmonics (THD)

The voltage harmonics is within range as per IEEE standards but current harmonics is too high especially in R-Phase with average value of 453%. This is on account of drastic reduction in active power at night time but the harmonic current remaining constant. Refer ANNEXURE – D for detailed data






Figure 24 Power Factor

The current APFC is not able to maintain the Power Factor and the PF is not same in all three phases because of load imbalance. Refer ANNEXURE -D for detailed data





---


### Energy Audit instruments

Please note all equipment are calibrated by a NABL accredited lab and hold valid calibration certificate.

Sr. No.	Name of the Instrument	Number
1	Solar PV Module Testor	Metrel MI3108
2	Thermal Imager	Testo 880
3	Clamp Meter	Metrel MD 9231




Solar plant photos



*Handwritten signature in blue ink.*




Meter & Distribution Panel Photos



*Kapal*





*Shree*





## Annexure A

### GIPE meter data

Sr. No.	Building Name	Consumer Number	Contract Demand (kVA)
1	GIPE university		
1	Staff Quarters : A1	170010981622	0.5
2	A2	170010981606	0.5
3	A3	170010981550	0.5
4	A4		
5	A5	170010981592	0.5
6	A6	170010981614	0.5
7	A7	170010981568	0.5
8	A8	170010981584	0.5
9	B1	170010981436	0.5
10	B3	170010981452	0.5
11	C1	170010980634	0.5
12	C2	170010981517	0.5
13	C3	170010981495	0.5
14	C5	170010980642	0.5
15	C6	170010981525	0.5
16	C7	170010981509	0.5
17	C8	170010980561	0.5
18	D1	170010983447	0.5
19	D2	170010983439	0.5
20	D3	170010983455	0.5
21	D4	170010983421	0.5
22	E1	160260577902	3
23	E2	160260577911	3
24	E3	160260577929	3
25	E4	160260577937	3
26	E5	160260577945	3
27	E6	160260577953	3
28	E7	160260577961	3
29	E8	160260577970	3
30	F1	160260577996	4
31	F2	160260578003	4
32	F3	160260578011	4
33	F4	160260578020	4
34	F5	160260578038	4
35	F6	160260578046	4
36	F7	160260578054	4



---

37	F8	160260578062	4
38	G1	160260600289	5
39	G2	160260600297	5
40	G4	160260600319	5
41	G7	160260600378	1
42	G8	160260600343	1
43	Quarter 8	170017720000	0.5
44	Quarter 9	170017720018	0.5
45	Quarter 10	170017720026	0.5
46	Quarter 11	170017720034	0.5

### Annexure B

GIPE load data

Annexure C – Thermal imaging data

Annexure D – Power analyzer raw data

